

Honeywell | Industrial & Commercial Thermal



Solenoid valves for gas VGP

Technical Information · GB 3 Edition 10 111

- Safety valves for gas
- Compact design saves space
- Low power consumption
- Simplified equipment saves costs
- EC type-tested and certified
- AGA approved
- Certified by Gosstandart pursuant to GOST-TR









Contents

Solenoid valves for gas VGP	
Contents	2
L Application	3
1.1 Examples of application	
2 Certification	
3 Function	5
3.1 Animation	
4 Flow rate	7
5 Selection	
5.1 Type code	
6 Project planning information	
6.1 Installation	
6.2 Wiring	9
7 Technical data	10
7.1 Dimensions	10
8 Maintenance cycles	11
Feedback	12

1 Application



Gas solenoid valves VGP for safeguarding and controlling the air and gas supply to gas burners and gas appliances. For use in gas control and safety systems in industrial and commercial heat generation, such as the foodstuffs and ceramics industries.


1.1 Examples of application



Ceramics industry: roller hearth kiln



Ceramics industry: intermittent shuttle kiln



Ceramics industry: intermittent shuttle kiln

2 Certification

EC type-tested and certified



pursuant to

Gas Appliances Directive (2009/142/EC) in conjunction with EN 161,

Meets the requirements of the

- Low Voltage Directive (2006/95/EC),
- EMC Directive (2004/108/EC).

AGA approved



Australian Gas Association, Approval No.: 5567 www.aga.asn.au/product_directory

Approval for Russia





 $Certified \ by \ Gosstandart \ pursuant \ to \ GOST-TR.$

Approved by Rostekhnadzor (RTN).

Scan of the approval for Russia (RUS) – see www. docuthek.com → Elster Kromschröder → Products → 03 Valves and butterfly valves → Solenoid valves for gas VGP → Kind of document: Certificate → VGP B00071 (nat. Zertifikat Russland) (RUS)

3 Function





The gas solenoid valve VGP is closed when de-energized.

Opening: the applied AC voltage is rectified (the rectifier adapter must be installed for this) and generates a powerful magnetic field in the solenoid coil. The magnetic field attracts the iron core and lifts the valve disc from the valve seat, acting against the effective inlet pressure and the closing spring force. The gas solenoid valve VGP opens and the gas supply is released.

Closing: when the voltage is disconnected, the magnetic field collapses and within 1 s, the closing spring pushes the iron core with valve disc back onto the valve seat, assisted by the inlet pressure. The gas solenoid valve VGP closes and the gas supply is stopped.



3.1 Animation


The interactive animation shows the function of the gas solenoid valve VGP.

Click on the picture. The animation can be controlled using the control bar at the bottom of the window (as on a DVD player).

To play the animation, you will need Adobe Reader 9 or a newer version. If you do not have Adobe Reader on your system, you can download it from the Internet.

If the animation does not start to play, you can download it from the document library (Docuthek) as an independent application.

4 Flow rate



Example:

gas type: natural gas, flow rate = $20 \text{ m}^3/\text{h}$, Δp from diagram = 8 mbar, solenoid valve VGP 20

① = natural gas (ρ = 0.80 kg/m³)

- ② = town gas (ρ = 0.64 kg/m³)
- $3 = LPG (\rho = 2.01 \text{ kg/m}^3)$
- $4 = air (\rho = 1.29 \text{ kg/m}^3)$

5 Selection

Тур	R	01	02	W	Q	5	6
VGP 10	•	_	•	•	•	•	•
VGP 15	•	-	•	•	•	•	•
VGP 20	•	•	-	•	•	•	•
VGP 25	•	•	-	•	•	•	•

● = standard

Order example


VGP 20R01W6

5.1 Type code


Code	Description
VGP	Gas solenoid valve
10, 15, 20, 25	Nominal diameter
R	Rp internal thread
01 02	p _u max. 150 mbar p _u max. 200 mbar
Q W	Mains voltage 120 V AC; 50/60 Hz Mains voltage 230 V AC; 50/60 Hz
5 6	Connection via rectifier adapter without standard socket Connection via rectifier adapter and standard socket

6 Project planning information

6.1 Installation




Installation position: black solenoid actuator in the vertical upright position or tilted up to the horizontal, not upside down.



The gas solenoid valve VGP must not be in contact with masonry. Minimum clearance 20 mm.

Do not store or install the unit in the open air.




Sealing material and dirt, e.g. thread cuttings, must not be allowed to get into the valve housing.

Install a filter (GFK) upstream of every system.



The solenoid body heats up during operation depending on ambient temperature and voltage.

6.2 Wiring



Wiring to EN 60204-1.

It is absolutely necessary to install a rectifier adapter (included in the delivery).

7 Technical data

Gas types: natural gas, town gas, LPG (gaseous), biologically produced methane (max. $0.1\,\%$ -by-vol. H_2S) or clean air; other gases on request. The gas must be dry in all temperature conditions and must not contain condensate

Opening time: 0.5 s.

Closing time: < 1 s.

Ambient temperature: -20 to +60°C. Storage temperature: -20 to +40°C.

Safety valve:

Class A Group 2 pursuant to EN 161,

Mains voltage:

230 V AC, +10/-15%, 50/60 Hz, 120 V AC, +10/-15%, 50/60 Hz.

Electrical connection:

plug with socket to EN 175301-803.

Power consumption:

Тур	120/230 V~ [W]
VGP 10	26
VGP 15	26
VGP 20	35
VGP 25	35

Enclosure: IP 54.

Duty cycle: 100%.

Power factor of the solenoid coil: $\cos \varphi = 1$.

Solenoid coil insulation: class F insulating material.


Switching frequency: any.

Valve housing: aluminium,

valve disc: Perbunan.

Internal thread: Rp to ISO 7-1.

7.1 Dimensions



Data table [mm]

Туре	Conne	ection	Dimensions				p _u max.	Weight
			L	H1	H2	Е		
	Rp	DN	mm	mm	mm	mm	mbar	g
VGP 10	3/8	10	71	89	16	77	200	500
VGP 15	1/2	15	71	89	16	77	200	480
VGP 20	3/4	20	91	105	23	78	150	800
VGP 25	1	25	91	105	23	78	150	780

8 Maintenance cycles

At least once a year, twice a year in the case of biologically produced methane.

Feedback

Finally, we are offering you the opportunity to assess this "Technical Information (TI)" and to give us your opinion, so that we can improve our documents further and suit them to your needs.

Clarity

Found information quickly
Searched for a long time
Didn't find information
What is missing?

Comprehension Coherent

Too complicated
No answer

Scope

Too little Sufficient

Too wide No answer



No answer

Use

To get to know the product
To choose a product
Planning
To look for information

Navigation

No answer

I can find my way around I got "lost"

My scope of functions

Technical department

Sales

No answer

Remarks

Contact

Elster GmbH Postfach 2809 · 49018 Osnabrück Strotheweg 1 · 49504 Lotte (Büren) Germany Tel +495411214-0

Fax +49 541 1214-0 Fax +49 541 1214-370 info@kromschroeder.com www.kromschroeder.com The current addresses of our international agents are available on the Internet: www.kromschroeder.de/Weltweit.20.0.html?&L=1

We reserve the right to make technical modifications in the interests of progress. Copyright © 2016 Elster GmbH All rights reserved.

